

Subject: 2020 93308 Lidl - lack of details
Date: 03 December 2020 18:02:45

Former Spotted Cow

With regards to this application, the area around the boundary adjacent to the public footpath does not appear to have been amended. The public footpath is not included in the proposals, and we have made comments on this previously.

Public footpath Huddersfield has a recorded width of 1.5 m and runs along the eastern boundary. The proposal does not indicate how the path will be dealt with. The block plan indicates that the existing fence/railings will be retained. However, the proposed retaining wall indicates a 8m or 9m retaining wall with open boarded timber fencing to rear or the wall is shown on the retaining wall elevations.

Please clarify how the design and retaining wall will be incorporated in with the footpath.

Sharon